

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 155

Dated: 21.06.2023

It is certified that an inspection team headed by Ranjeet Barwa (ZHO)
 (Name of Officers with designation) from Raipur Municipal Corporation Zone 3
 (Name of Department/ Office) inspected the ADARSH VIDYALAYA, ADARSH NAGAR MOWA
 (Name & Address of the school) on 20.06.2023 (date of inspection) and found that the
ADARSH VIDYALAYA MOWA (Name of school) has safe drinking water facilities for the
 students and members of staff of the institution and is maintaining the hygienic sanitation
 condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T.
 Govt.

The above is valid for a period of one year

Signature with Seal: Raj
 ZONE COMMISSINER
 ZONE NUMBER 3
 MUNICIPAL CORPORATION
 Name Rakesh Awadhya
 Designation Zone Commissioner
 Name & Address of the Office / Department Mupl Corp
Raipur

To

PRINCIPAL,ADARSH VIDYALAYA MOWAADARSH NAGAR, NEAR MOWAPOLICE THANA, RAIPUR (C.G)PIN-492001

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Report No. - 175
Date - 16/06/2023

MUNICIPAL CORPORATION RAIPUR
WATER ANALYSIS LABORATORY RAIPUR (C.G.)
WATER ANALYSIS REPORT

Sample Sent By : Executive Engineer, Zone no.- 03, Municipal Corporation Raipur (C.G.).
Particulates : (1) Sample Collected From :- (By Party) Adarsh Vidyalaya, Ward- Rani Laxmi Bai
Ward No.- 10, Raipur.
(2) Date of Collection :- 12/06/2023
(3) Date of Delivery to Laboratory :- 12/05/2023
(4) Date of Analysis :- 12/05/2023 to 14/06/2023

	Parameters	Unit	Acceptable limit As per CPHEEO Manual and IS:10500	Permissible limit	Result
(A)	Physical Exam.				
	Turbidity	N.T.U.	5	10	1.0
	Colour	T.C.U.	5	25	Nil
	Taste & Odour	-	Unobjectionable	Unobjectionable	Unobject.
(B)	Chemical Exam.				
	P.H.Value	Scale	7.0 to 8.5	<6.5 or >9.2	7.1
	Total Alkalinity	Mg/l	200	600	20
	Total Acidity	----"----	-	-	-
	Total Dissolved solids	----"----	500	2000	74
	Total Hardness as CaCO ₃	----"----	200	600	32
	Calcium (Ca)	----"----	75	200	8.0
	Magnesium (Mg)	----"----	<=30	100	2.88
	Iron as (Fe)	----"----	0.1	1.0	0.1
	Manganese (Mn)	----"----	0.05	0.3	Nil
	Chloride (Cl)	----"----	200	1000	8.0
	Sulphate (SO ₄)	----"----	200	400	9.60
	Flourides (F)	----"----	1.0	1.5	Nil
	Nitrate (NO ₃)	----"----	45	45	1.0

(C)	Bacteriological Exam :-	Coli Count	M.P.N	
	M.P.N. Index 100 ml	0	Excellent	0
	Presumptive Coli form	0 to 3	Satisfactory	-----
	Bacteria or Faecal Coliform	3 to 10	Suspicious	-----
		Above 10	Unsatisfactory	-----

ASSISTANT ENGINEER,
FILTER PLANT,
NAGAR PALIK NIGAM, RAIPUR (C.G.)

CHEMIST
FILTER PLANT
MUNICIPAL CORPORATION
RAIPUR